

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE <b>J</b>		PAGE OF PAGES <b>1   4</b>	
2. AMENDMENT/MODIFICATION NO. <b>0003</b>		3. EFFECTIVE DATE <b>12-Sep-2003</b>		4. REQUISITION/PURCHASE REQ. NO. <b>W16ROE-3175-7724</b>		5. PROJECT NO.(If applicable)	
6. ISSUED BY USA ENGINEER DISTRICT, NEW YORK ATTN: CENAN-CT ROOM 1843 26 FEDERAL PLAZA (DACW51) NEW YORK NY 10278-0090		CODE <b>DACW51</b>		7. ADMINISTERED BY (If other than item 6)  <b>See Item 6</b>		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. <b>DACW51-03-B-0017</b>	
				X		9B. DATED (SEE ITEM 11) <b>04-Aug-2003</b>	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. <b>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) <b>Beach Erosion Control and Hurricane Protection Project, East Rockaway Inlet to Rockaway Inlet and Jamaica Bay, NY, Beach Restoration Contract 8</b> 1. The purpose of this amendment is to revised the section 00010, item 0002 Hydraulic Beachfill: The quantity of Hydraulic Beachfill is changed from 1,300,000 cubic yard to 1,060,000 cubic yard as shown on page 2 of this document. 2. To incorporated the contractors questions and answer "for information only" as shown on page 3 and 4 of this document. 3. The bid opening date is changed from 15 September 2003 at 11:00 AM to 17 September 2003 at 11:00 AM, local time in room 1843. 4. All other terms and conditions remain unchanged.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  <b>11-Sep-2003</b>	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

## SUMMARY OF CHANGES

## SECTION 00010 - SOLICITATION CONTRACT FORM

5. All bidders must acknowledge receipt of this amendment by the date specified in the solicitation (or as amended) by one of the following methods; in the space provided on te SF 1442, by separate letter, or by telegram, or signing block 15 below. FAILURE TO ACKNOWLEDGE AMENDMENTS BY THE DATE AND TIME SPECIFIED MAY RESULT IN REJECTION OF YOUR BID IN ACCORDANCE WITH THE LATE BID, LATE MODIFICATIONS OF BID OR LATE WITHDRAWAL OF BIDS (FAR 14.304).

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001		1	Lump Sum		
	Mobilization & Demobilization for FFP Hydraulic Beach Fill PURCHASE REQUEST NUMBER: W16ROE-3175-7724				

---

NET AMT	\$	
---------	----	--

FOB: Destination

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0002		1,060,000	Cubic Yard		
	Hydraulic Beach Fill FFP PURCHASE REQUEST NUMBER: W16ROE-3175-7724				

---

NET AMT	\$	
---------	----	--

FOB: Destination

TOTAL BASE BID LINE ITEMS #0001 AND 0002-----\$

**NOTICE TO BIDDERS**

Failure of the bidder to Acknowledge receipt of this Amendment in Item 19 of Standard Form 1442 (Pg. 00010-2) may result in REJECTION of the bid.

IFB NO. DACW51-03-B-0017

Amendment No. 3

Department of the Army, NYD  
Corps of Engineers  
New York, NY 10278-0090

AMENDMENT NO. 3 TO SPECIFICATIONS FOR BEACH EROSION CONTROL AND HURRICANE PROTECTION PROJECT, EAST ROCKAWAY INLET TO ROCKAWAY INLET AND JAMAICA BAY, NEW YORK, BEACH RESTORATION CONTRACT 8

**TO BIDDERS**

1. Specifications Section 00010 Item 0002 Hydraulic Beach fill: The quantity of Hydraulic Beachfill is changed to 1,060,000 cy.

**Questions and Answers (For Information Only)**

1. Amendment 0002 provides a new survey of the required beachfill area. Our quantity takeoff of this new survey indicates that approximately 750,000 cy of material is required to fill the beach template. However, the advertised bid quantity remains at 1,300,000 cy. Please clarify.

**Response:** The advertised bid quantity in Section 00010 is being revised to 1,060,000 cy under amendment # 3.

2. Our quantity takeoff of the required beachfill further indicates that between Monuments R45 and R60, and between Monuments R71 and R83, a total of only 44,000 cy of beachfill is required. This equates to an average fill quantity of only 5 cy per lineal feet of beach within these two reaches. It is impossible to directly place (pump) this small amount of fill into section using the ocean going dredges that are appropriate for this project without drastically over-building these sections above and beyond the design template. Is it the Government's intention to design the beachfill sections in these reaches with a 5 cy per lineal foot requirement? We respectfully suggest that any requirement for beachfill within these two reaches be eliminated from the solicitation, or that the beach template be redesigned to accommodate at least 50 cy of beachfill per lineal foot. Alternatively, would the Contractor be allowed to stockpile material in adjacent reaches and truck the material into place?

**Response:** It is the intent for the subject areas indicated to be filled by material stockpiled and trucked to those areas.

3. Our quantity takeoff of the required beachfill also indicates that between Monuments R60 and R71, a total of only 68,000 cy of beachfill is required. This equates to an average fill quantity of only 27 cy per lineal feet of beach within this reach. This size of beachfill template is also extremely difficult and costly to construct. Is it the Government's

intention to design the beachfill sections in this reach with a 27 cy per lineal foot requirement? We respectfully suggest that any requirement for beachfill within these two reaches be eliminated from the solicitation, or that the beach template be redesigned to accommodate at least 50 cy of beachfill per lineal foot. Alternatively, would the Contractor be allowed to stockpile material in adjacent reaches and truck the material into place?

**Response:** It is the intent for the subject areas indicated to be filled by material stockpiled and trucked to those areas.

4. The design template for beachfill profiles R83 & R84 shown on sheet 10 of 22 of the drawings indicate a top of berm height at Elevation 0.0'. All other profiles indicate a top of berm height at Elevation +10'. Please clarify.

**Response:** The design template for beachfill profiles R83 & R84 shown on sheet 10 of 22 of the drawings should indicate a top of berm height at Elevation +10'.

5. This Amendment shall be attached to the specifications and shall be a part thereof.

ELLA SNELL  
CONTRACTING OFFICER  
C, CONTRACTING DIVISION

(End of Summary of Changes)